



AMALA INSTITUTE OF MEDICAL SCIENCES

(ISO 9001:2008 Certified)

Amala Nagar, Thrissur - 680 555




OPERATING DATA - WASTE WATER TREATMENT PLANT

Date	Plant operations HRS			Flow rate m ³ /hr	Total treated water/day	Oil Removal	Sludge removal	back washing filters	Chemicals, ppm			pH	Remarks	Signature
	From	To	Total						NaOCl	NaOH	PAC			
04/01/26	08:00	08:00	2HRS	26.66	640M ³	✓	✓	✓	4.2	21	44	07.20		Mabesh
05/01/26	08:00	08:00	2HRS	26.95	647M ³	✓	✓	✓	4.4	23	44	07.20		Mabesh
06/01/26	08:00	08:00	2HRS	27.04	649M ³	✓	✓	✓	4.1	22	43	07.10		Mabesh
07/01/26	08:00	08:00	2HRS	27.33	656M ³	✓	✓	✓	4.3	24	45	07.00		Mabesh
08/01/26	08:00	08:00	2HRS	27.00	648M ³	✓	✓	✓	4.5	24	41	07.10		Mabesh
09/01/26	08:00	08:00	2HRS	27.16	652M ³	✓	✓	✓	4.3	23	43	07.00		Mabesh
10/01/26	08:00	08:00	2HRS	26.91	646M ³	✓	✓	✓	4.2	22	43	07.20		Mabesh
11/01/26	08:00	08:00	2HRS	27.29	655M ³	✓	✓	✓	4.1	23	42	07.00		Mabesh
12/01/26	08:00	08:00	2HRS	27.41	658M ³	✓	✓	✓	4.3	24	44	07.00		Mabesh
13/01/26	08:00	08:00	2HRS	27.25	654M ³	✓	✓	✓	4.4	22	45	07.00		Mabesh
14/01/26	08:00	08:00	2HRS	26.87	645M ³	✓	✓	✓	4.2	24	46	07.20		Mabesh
15/01/26	08:00	08:00	2HRS	26.79	643M ³	✓	✓	✓	4.1	21	42	07.20		Mabesh
16/01/26	08:00	08:00	2HRS	26.70	641M ³	✓	✓	✓	4.2	21	43	07.10		Mabesh
17/01/26	08:00	08:00	2HRS	26.75	642M ³	✓	✓	✓	4.3	23	45	07.10		Mabesh
18/01/26	08:00	08:00	2HRS	27.37	657M ³	✓	✓	✓	4.4	23	46	07.00		Mabesh
19/01/26	08:00	08:00	2HRS	27.12	651M ³	✓	✓	✓	4.1	22	43	07.00		Mabesh
20/01/26	08:00	08:00	2HRS	26.91	646M ³	✓	✓	✓	4.3	21	45	07.20		Mabesh

Note : NaOCl - Sodium hypochlorite, NaOH - Caustic soda, PAC - Poly aluminium chloride

Arav Kumar Dadas
Name & Signature of Operator

Arav



MABESH N. N. K.
Name & Signature of Supervisor
AMALA INSTITUTE OF MEDICAL SCIENCES
AMALA NAGAR, THRISSUR-680 555

Betsy

DR. BETSY THOMAS
MD, FRCOG, DNB, MICOG
PRINCIPAL

JIJO LAZARUS T.
Civil & Environmental Engg
Amala Institute of Medical Sciences
Thrissur, Kerala

Name & Signature of plant In-charge