



STATEMENT

This is to state that periodic checking of water for safety is done by Microbiology department. Documents and supporting certificates of the same can be produced on demand.

Date: 29/11/25
Place: Thrissur

Betsy

Dr. Betsy Thomas
Principal
Dr. BETSY THOMAS
MD, FRCOG, DNB, MICOG
PRINCIPAL
AMALA INSTITUTE OF MEDICAL SCIENCES
AMALA NAGAR, THRISSUR-680 555



AMALA INSTITUTE OF MEDICAL SCIENCES

Amala Nagar, Thrissur

BACTERIOLOGICAL ANALYSIS OF WATER

WATER CULTURE BY PRESUMPTIVE COLIFORM COUNT

Lab No:	W -05
Source of Water:	CHAVARA HOSTEL DRINKING WATER
Date and time of Collection:	03/01/2026 at 11:25am
Requested by:	Rev. Fr. Julious Arakkal CMI
Date and time of Report:	05/01/2026 at 10:30am

Presumptive coliform count / 100 ml of water	Category	Result
0	Class I	Excellent

Interpretation:


Presumptive coliform count / 100 ml

0 → Class I → Excellent


1-3 → Class II → Satisfactory




4-10 → Class III → Suspicious

> 10 → Class IV → Unsatisfactory



Prof. & HOD
Dept. of Microbiology



Amala Institute of Medical Sciences (An Undertaking of Amala Cancer Hospital Society)
Affiliated to Kerala University of Health Sciences Accredited by KUHS with QAS A+ Grade &
NABH & NABL Accredited & ISO 9001:2015 Certified, Amala Nagar P.O, Thrissur, Kerala.
Ph: +91 487 2304000, 2304070 | Fax: +91 487 2307969 | urooncology@amalaaims.org
www.amalaaims.org | Follow us on   

AMALA INSTITUTE OF MEDICAL SCIENCES

Amala Nagar, Thrissur

BACTERIOLOGICAL ANALYSIS OF WATER

WATER CULTURE BY PRESUMPTIVE COLIFORM COUNT

Lab No:	W-04
Source of Water:	OP CANTEEN NORMAL WATER
Date and time of Collection:	01/01/2026 at 12:50pm
Requested by:	Rev. Fr. Julious Arakkal CMI
Date and time of Report:	03/01/2026 at 10:30am

Presumptive coliform count / 100 ml of water	Category	Result
0	Class I	Excellent

Interpretation:

Presumptive coliform count / 100 ml

0 → Class I → Excellent

1-3 → Class II → Satisfactory

4-10 → Class III → Suspicious

> 10 → Class IV → Unsatisfactory




Prof. & HOD
Dept. of Microbiology




Amala Institute of Medical Sciences (An Undertaking of Amala Cancer Hospital Society)
Affiliated to Kerala University of Health Sciences Accredited by KUHS with QAS A+ Grade &
NABH & NABL Accredited & ISO 9001:2015 Certified, Amala Nagar P.O, Thrissur, Kerala.
Ph: +91 487 2304000, 2304070 | Fax: +91 487 2307969 | urooncology@amalaims.org
www.amalaims.org | Follow us on

TAP WATER CULTURE -2026

SL. NO	DEPARTMENT		AREA
1.	January	OT scrub basin tap (any one tap)	LR OT
		Hand wash basin tap in a ward that caters to maximum number of patients	Ward 23
2.	February	ICU hand wash basin tap	GICU,PSICU,IDICU,NICU
3.	March	Casualty/Emergency ward hand wash basin tap	ED
4.	April	OT scrub basin tap (any one tap)	General OT
		Hand wash basin tap in a ward that caters to maximum number of patients	Ward 38
5.	May	ICU hand wash basin tap	CICU,MICU,RICU
6.	June	Casualty/Emergency ward hand wash basin tap	ED
7.	July	OT scrub basin tap (any one tap)	CVS OT
		Hand wash basin tap in a ward that caters to maximum number of patients	Ward 2
8.	August	ICU hand wash basin tap	CVS ICU,CCU,SSICU
9.	September	Casualty/Emergency ward hand wash basin tap	ED
10.	October	OT scrub basin tap (any one tap)	SS OT
		Hand wash basin tap in a ward that caters to maximum number of patients	Ward 5
11.	November	ICU hand wash basin tap	PICU,SICU,Onco ICU
12.	December	Casualty/Emergency ward hand wash basin tap	ED


HIPC Department



AMALA INSTITUTE OF MEDICAL SCIENCES

Amala Nagar, Thrissur

BACTERIOLOGICAL ANALYSIS OF WATER

WATER CULTURE BY PRESUMPTIVE COLIFORM COUNT



Lab No:	W-1
Source of Water:	IP canteen R.O water
Date and time of Collection:	01/08/2025 at 12:20pm
Requested by:	Rev. Fr. Julious Arakkal CMI
Date and time of Report:	04/08/2025 at 10:30am

Presumptive coliform count / 100 ml of water	Category	Result
0	Class I	Excellent

Interpretation:

Presumptive coliform count / 100 ml

0 → Class I → Excellent

1-3 → Class II → Satisfactory

4-10 → Class III → Suspicious

> 10 → Class IV → Unsatisfactory

Betsy

Dr. BETSY THOMAS

MD, FRCOG, DNB, MICOG

PRINCIPAL

AMALA INSTITUTE OF MEDICAL SCIENCES
AMALA NAGAR, THRISSUR-680 555



Prof. & HOD

Dept. of Microbiology



Amala Institute of Medical Sciences (An Undertaking of Amala Cancer Hospital Society)
Affiliated to Kerala University of Health Sciences Accredited by KUHS with QAS A+ Grade &
NABH & NABL Accredited & ISO 9001:2015 Certified, Amala Nagar P.O, Thrissur, Kerala.
Ph: +91 487 2304000, 2304070 | Fax: +91 487 2307969 | urooncology@amalaims.org
www.amalaims.org | Follow us on [Social Media Icons]